

Proposed Code Change State Form 41186R

RETURN TO: INDIANA DEPARTMENT OF HOMELAND SECURITY CODE SERVICES SECTION 302 W. Washington Street Room W246

Indianapolis, IN 46204

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY - Dashed line through material to be deleted, underline material to be added)

FOR OFFICE USE ONLY

Received

Code 62.5-09

Use second sheet for any material requiring more space.		
Code Title		Edition
Indiana Residential Code		2009
Section number and title		Page
E3902.11		683
Proponent Title		
Charlie Eldridge	Consultant	
Address		Phone
551 Grassy Ln., Indianapolis, IN 46217		(317) 370-3444
PROPOSED CODE CHANGE (Check One)		
Change to read as follows Add to read as follows Delete and substitute as follows Delete without substitution E3902.11 Arc-fault circuit-interrupter protection. All branch circuits that supply 120-volt, single-phase, 15- and 20-ampere outlets		
installed in family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms, sunrooms, recreations rooms, closets, hallways and similar rooms or areas shall be protected by a combination type arc-fault circuit interrupter installed to provide protection of the branch circuit. Exception:		
Where a combination AFCI is installed at the first outlet to provide protection for the remaining portion of the branch circuit, the portion of the branch circuit between the branch circuit overcurrent device and such outlet shall be wired with metal outlet and junction boxes and RMC, IMC, EMT or steel armored cable, Type AC meeting the requirements of Section E3908.8.		
2. AFCI protection is not required for a branch circuit supplying only a fire alarm system where the branch circuit is wired with metal outlet and junction boxes and RMC, IMC, EMT or steel armored cable Type AC meeting the requirements of Section E3908.8.		
REASON AND FISCAL IMPACT		
This text to delete was extracted from the 2005 Indiana Residential Code.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		